

Summary of Water Quality Data

DS Waters of America
Lakeside Bottling Plant

Data from 1990 - 2003

Constituent	Unit Concentration	Groundwater Average (4 wells)	Effluent Average	Basin Plan Objectives
TDS	mg/L	1189	878	1000
Chloride	mg/L	313	239	400
Sulfate	mg/L	272	204	500
pH	units	5.7 – 8.7	7.4	6.0 – 9.0*
*—within these limits at all times				